

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7270-0900:126 Page 1 of 1

CATEGORY: Heat Detector

LISTEE: Fike Corporation, 704 S. 10th Street, Blue Springs, MO 64015
Contact: Sean Titus (816) 229-340 FAX (816) 229-5082

DESIGN: Models 60-1020 and 60-1022 heat detectors. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with the listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, temperature & electrical ratings and UL label.

APPROVAL: Listed as system heat detectors when used in conjunction with listed compatible bases (CSFM Listing No. 7300-0900:123) and separately listed compatible control units.

XLF: 7270-0410:119

07-26-2002 BH



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 21, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**